



November 27, 2023

Village of Theodore
Box 417
Theodore SK.
S0A 4C0

Attention: Waterworks Owner

RE: Rescinding Precautionary Drinking Water Advisory – Village of Theodore

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **“Precautionary Drinking Water Advisory” (PDWA)** issued by the Water Security Agency for Village of Theodore’s potable water system at be rescinded as of November 27, 2023.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The turbidity in the system is within regulatory requirements;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements and;
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Theodore in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 621-2230.

Sincerely,

A handwritten signature in black ink, appearing to read "Rick Sheichuk".

Rick Sheichuk
Environment Officer
Water Security Agency
Ph. (306) 621-2230
Fx. (306) 786-1495

cc. Ries Mansuy, Water Security Agency
Kari Engle-Carter, Saskatchewan Health Authority - Yorkton