



September 28, 2018

File: 21020-50/WW/OP/Theodore

Village of Theodore  
Box 417  
Theodore SK.  
S0A 4C0

**Attention:** Waterworks Owner

**RE: Rescinding Precautionary Drinking Water Advisory - Village of Theodore**

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **"Precautionary Drinking Water Advisory" (PDWA)** issued by the Water Security Agency for Village of Theodore's potable water system at be rescinded as of 8:30 am Friday, September 28, 2018.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The repairs or maintenance has been complete;
- The turbidity in the system is within regulatory requirements;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements and;
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Theodore in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 786-1424.

Sincerely,

A handwritten signature in black ink, appearing to read "Rick Sheichuk".

Rick Sheichuk  
Environmental Project Officer  
Environmental & Municipal Management Services Division  
Water Security Agency  
Ph. (306) 786-1424  
Fx. (306) 786-1495

cc. Greg Holovach, Water Security Agency – Environmental and Municipal Management Services - South  
Gilbert Combres, Senior Public Health Inspector, Sunrise Health Region